


NOTES:

1. REFER TO SMARTPLATE EV APPLICATIONS GUIDE FOR BUFFER TANK SIZING.
2. REFER TO SMARTPLATE EV INSTALLATION DRAWINGS FOR RECOMMENDED DOMESTIC PIPING INSTALLATION.
 SD-A-1198
 SD-A-1199
 SD-A-1200
 SD-A-1201
 SD-A-1202
 SD-A-1203
3. ONE OR MULTIPLE BYPASS LINES MAY BE REQUIRED. BYPASS PIPING AND ISOLATION VALVE TO BE FIELD SUPPLIED. SEE APPLICATION GUIDE FOR REFERENCE.

 <small>A WATTS Brand</small>	100 ORITANI DRIVE BLAUVELT, NY 10913 aerco.com
SMARTPLATE EV MULTIPLE UNITS WITH BOILER SIDE BUFFER TANK AS A ZONE	
DWN. BY <u>K.S.</u> DATE <u>071420</u> SCALE <u>NTS</u> SIZE <u>A</u> CHKD. _____ APPD. _____ REV. BY <u>K.S.</u> DATE <u>041421</u>	SD-A-1206 REV. B