



## AERCO AM SERIES – POTABLE APPLICATIONS Primary Loop Design Guidelines

### MINIMUM AND MAXIMUM FLOW RATES

	AM 399	AM 500	AM 750	AM 1000
<b>Minimum Water Flow at Min. Fire (GPM)</b>	11	12	12	12
<b>Minimum Water Flow at Full Fire (GPM)</b>	22	24	36	48
<b>Maximum Water Flow (GPM)</b>	40	40	60	80

The following primary/secondary piping design guidelines should be used for AERCO AM Series potable water applications. A 20 mesh strainer (or finer) is required at each inlet. Water flow rates and pressure drops shown below are for the primary loop. Flow rates vary with system design parameters. **The primary loop fittings and strainer pressure drops shown below are examples only – actual pressure drops will vary depending on actual piping layout and strainer size/type used.**

	<u>AM 399</u>	<u>AM 500</u>	<u>AM 750</u>	<u>AM 1000</u>
<b>MAXIMUM Potable water hardness = 10 grains per gallon</b>				
Water Flow (GPM)	22	24	36	48
Water Press. Drop (Ft. of Hd.) across AM Series	10	14	14	17
Strainer ΔP (Ft. of Hd.) – ('Y' Strainer, 20 mesh) plus ΔP (Ft. of Hd.) – (20' SCH.40, 4 x 90°, 2 x reducing couplings, 2 x Ball Valve)	2.15	2.15	1.65	2.25
<b>Total Primary Loop ΔP (Ft. of Hd.)</b>	<b>12.15</b>	<b>16.15</b>	<b>15.65</b>	<b>19.25</b>
Recommended AERCO Pump+Circuit Setter Kit for piping configurations not exceeding the above example	<b>99237-1</b>	<b>99237-2</b>	<b>99237-2</b>	<b>99237-5</b>
Kit includes: Pump Flange Size	1-1/4"	1-1/4"	1-1/2"	1-1/2"
Kit includes: Circuit Setter Size (NPT)	1-1/2"	1-1/2"	2"	2"
Recommended AERCO AM DHW Installation Kit (Installation Kit <b>already includes</b> above Pump/Circuit setter kit, plus Strainer, Isolation Valve, and pipe fittings).	<b>58135-1</b>	<b>58135-2</b>	<b>58135-2</b>	<b>58135-3</b>
Installation Kit designed for inlet/outlet piping diameter: Strainer and Isolation valves sizes (NPT):	1-1/2"	2"	2"	2"

	<u>AM 399</u>	<u>AM 500</u>	<u>AM 750</u>	<u>AM 1000</u>
<b>MAXIMUM Potable water hardness = 18 grains per gallon</b>				
Water Flow (GPM)	37	37	60	75
Water Press. Drop (Ft. of Hd.) across AM Series	27	32	38	41
Strainer ΔP (Ft. of Hd.) – ('Y' Strainer, 20 mesh) plus ΔP (Ft. of Hd.) – (20' SCH.40, 4 x 90°, 2 x reducing couplings, 2 x Ball Valve)	1.88	1.88	2.20	3.05
<b>Total Primary Loop ΔP (Ft. of Hd.)</b>	<b>28.88</b>	<b>33.88</b>	<b>40.20</b>	<b>44.05</b>
Recommended AERCO Pump+Circuit Setter Kit for piping configurations not exceeding the above example	<b>99237-5</b>	<b>99237-5</b>	<b>99227-5</b>	<b>99227-5</b>
Kit includes: Pump Flange Size	1-1/2"	1-1/2"	2"	2"
Kit includes: Circuit Setter Size (NPT)	2"	2"	2-1/2"	2-1/2"
Recommended AERCO AM DHW Installation Kit (Installation Kit <b>already includes</b> above Pump/Circuit setter kit, plus Strainer, Isolation Valve, and pipe fittings).	<b>58135-3</b>	<b>58135-3</b>	<b>58135-4</b>	<b>58135-4</b>
Installation Kit designed for inlet/outlet piping diameter: Strainer and Isolation valves sizes (NPT):	2"	2"	2-1/2"	2-1/2"

NOTE: Units with outlet connections matching pipe size do not include reducer.